

Dataset Expocode 316420160319

Primary Contact **Name:** Sylvia Musielewicz
Organization: NOAA/PMEL
Address: 7600 Sand Point Way NE Seattle, WA 98115-6349
Phone: 206-526-6252
Email: Sylvia.Musielewicz@noaa.gov

Investigator **Name:** Dr. Adrienne Sutton
Organization: NOAA/PMEL
Address: 7600 Sand Point Way NE Seattle, WA 98115-6349
Phone: (206) 526-6879
Email: Adrienne.Sutton@noaa.gov

Investigator **Name:** Dr. Jan Newton
Organization: University of Washington
Address: Applied Physics Lab 1013 NE 40th St., Seattle, WA
Phone:
Email:

Investigator **Name:** Dr. John Mickett
Organization: University of Washington
Address: Applied Physics Lab 1013 NE 40th St., Seattle, WA
Phone:
Email:

Dataset **Funding Info:** NOAA
Initial Submission (yyyymmdd): 03/27/2018
Revised Submission (yyyymmdd):

Campaign/Cruise **Expocode:** 316420160319
Campaign/Cruise Name:
Campaign/Cruise Info:
Platform Type:
CO2 Instrument Type:
Survey Type: Moored Buoy
Vessel Name:
Vessel Owner:
Vessel Code: LaPu

Coverage **Start Date (yyyymmdd):** 20160319
End Date (yyyymmdd): 20160612
Westernmost Longitude: 124.95 W
Easternmost Longitude: 124.95 W
Northernmost Latitude: 47.967 N
Southernmost Latitude: 47.967 N

Variable **Name:** Date Time
Unit:
Description: Date and Time (UTC)

Variable **Name:** xCO2 SW (wet)
Unit:
Description: (umol/mol) Mole fraction of CO2 in air in equilibrium with the seawater at sea surface temperature and measured humidity.

Variable **Name:** CO2 SW QF
Unit:

Description: Flag for xCO2 sw (wet)

Variable

Name: H2O SW

Unit:

Description: (mmol/mol) Mole fraction of H2O in air from equilibrator.

Variable

Name: xCO2 Air (wet)

Unit:

Description: (umol/mol) Mole fraction of CO2 in air from airblock, 4 feet above the sea surface at measured humidity.

Variable

Name: CO2 Air QF

Unit:

Description: Quality Flag for xCO2 Air (wet)

Variable

Name: H2O Air

Unit:

Description: (mmol/mol) Mole fraction of H2O in air from airblock, 4 feet above the sea surface.

Variable

Name: Licor Atm Pressure

Unit:

Description: (hPa) Atmospheric pressure at the airblock, 4 feet above the sea surface.

Variable

Name: Licor Temp

Unit:

Description: (C) Temperature of the Infrared Licor 820 in degrees Celsius.

Variable

Name: MAPCO2 %O2

Unit:

Description: The percent oxygen of the surface seawater divided by the percent oxygen of the atmosphere at 4 feet above the sea surface. Disclaimer: The oxygen measurement is made in the equilibrated air. We have found that the oxygen does not come to complete equilibrium so any rapid changes in oxygen do not get properly captured using this system. Therefore, we tend to use the oxygen data only as a qualitative sense of the biology. It is not a quantitative measure.

Variable

Name: SST

Unit:

Description: (C) Sea Surface Temperature.

Variable

Name: Salinity

Unit:

Description: (PSU) Sea Surface Salinity.

Variable

Name: xCO2 SW (dry)

Unit:

Description: (umol/mol) Mole fraction of CO2 in air in equilibrium with the seawater at sea surface temperature (dry air).

Variable

Name: xCO2 Air (dry)

Unit:

Description: (umol/mol) Mole fraction of CO2 in air at the airblock, 4 feet above the sea surface (dry air).

Variable

Name: fCO2 SW (sat)

Unit:

Description: (uatm) Fugacity of CO₂ in air in equilibrium with the seawater at sea surface temperature (100% humidity). Since the measurements are taken at the sea surface, warming calculations are not necessary.

Variable

Name: fCO₂ Air (sat)

Unit:

Description: (uatm) Fugacity of CO₂ in air at the airblock, 4 feet above the sea surface (100% humidity).

Variable

Name: dfCO₂

Unit:

Description: Difference of the fugacity of the CO₂ in seawater and the fugacity of the CO₂ in air (fCO₂ SW - fCO₂ Air).

Variable

Name: pCO₂ SW (wet)

Unit:

Description: (uatm) Partial Pressure of CO₂ in air in equilibrium with the seawater at sea surface temperature (100% humidity)

Variable

Name: pCO₂ Air (wet)

Unit:

Description: (uatm) Partial Pressure of CO₂ in air at the airblock, 4 feet above the sea surface (100% humidity).

Variable

Name: dpCO₂

Unit:

Description: Difference of the partial pressure of CO₂ in seawater and air (pCO₂ SW - pCO₂ Air)

Variable

Name: pH SW

Unit:

Description: pH of Seawater (total scale)

Variable

Name: pH QF

Unit:

Description: Quality Flag for pH

Sea Surface Temperature

Location: 1m

Manufacturer: SeaBird

Model: SBE 16

Accuracy: < 0.01 (°C if units not given)

Precision: (°C if units not given)

Calibration: ~ Annually by SeaBird

Comments: Temperature data are internally recorded and collected during the equilibration period. Data are not post-calibrated. Annual drift for this deployment was minimal and does not impact the fCO₂ and pCO₂ calculations (within the degree of accuracy of the CO₂ measurement). Contact us if you would like the CTD post-calibration information.

Sea Surface Salinity

Location: 1m

Manufacturer: SeaBird

Model: SBE 16

Accuracy: < 0.05

Precision:

Calibration: ~ Annually by SeaBird

Comments: Conductivity data are internally recorded and collected during the equilibration period. Data are not post-calibrated. Annual drift for this deployment

was minimal and does not impact the fCO₂ and pCO₂ calculations (within the degree of accuracy of the CO₂ measurement). Contact us if you would like the CTD post-calibration information.

Atmospheric Pressure

Location:
Normalized to Sea Level:
Manufacturer:
Model:
Accuracy: (hPa if units not given)
Precision: (hPa if units not given)
Calibration:
Comments:

Atmospheric CO₂

Measured/Frequency: yes, 3hr cycle
Intake Location: unused
Drying Method: unused
Atmospheric CO₂ Accuracy: 1 uatm
Atmospheric CO₂ Precision: 0.6 uatm

Aqueous CO₂ Equilibrator Design

System Manufacturer:
Intake Depth: 14cm - 20cm
Intake Location:
Equilibration Type: Bubble Equilibrator
Equilibrator Volume (L): N/A
Headspace Gas Flow Rate (ml/min): ~600 cc/min
Equilibrator Water Flow Rate (L/min): N/A
Equilibrator Vented: Yes
Equilibration Comments:
Drying Method:

Aqueous CO₂ Sensor Details

Measurement Method: Absolute, non-dispersive infrared (NDIR) gas analyzer
Method details:
Manufacturer: Licor
Model: LI-820
Measured CO₂ Values:
Measurement Frequency: 3hr cycle
Aqueous CO₂ Accuracy: 2 uatm
Aqueous CO₂ Precision: 0.7 uatm
Sensor Calibrations:
Calibration of Calibration Gases: At the beginning of each sample, the instrument self-calibrates using a zero and high standard. The zero standard is generated by cycling a small amount of air through a soda lime chamber. The high standard is from a cylinder of calibrated standard reference gas, 451.11 umol/mol, from ESRL. ESRL standards are traceable to WMO x93 scale with a stated reproducibility of 0.06 micromole/mole. For more information on estimates of accuracy and precision of the MAPCO₂ system, see Sutton et al. 2014 (reference below).
Number Non-Zero Gas Standards:
Calibration Gases:
NOAA Earth System Research & Laboratory (ESRL)
Comparison to Other CO₂ Analyses:
Comments:
Method Reference:

Sutton, A.J., Sabine, C.L., Maenner-Jones, S., Lawrence-Slavas, N., Meinig, C., Feely, R.A., Mathis, J.T., Musielewicz, S., Bott, R., McLain, P.D., Fought, J., Kozyr, A., 2014b. A high-frequency atmospheric and seawater pCO₂ data set from 14 open ocean sites using a moored autonomous system. Earth Sys. Sci. Data, 6, doi: 10.5194/essd-6-353-2014, 353-366.

**Equilibrator
Temperature Sensor**

Location:
Manufacturer:
Model:
Accuracy: (°C if units not given)
Precision: (°C if units not given)
Calibration:
Comments:

**Equilibrator
Pressure Sensor**

Location:
Manufacturer:
Model:
Accuracy: (hPa if units not given)
Precision: (hPa if units not given)
Calibration:
Comments:

Other Sensor

Description:
Manufacturer: Maxtec Oxygen Sensor
Model: Max-250
Accuracy: 2.0% Full Scale over operating temperature range. 1.0% Full Scale @ constant temperature and pressure
Precision:
Calibration: Factory calibrated before purchase. Recalibrated to sea level atmospheric air every 7 days
Comments:

Other Sensor

Description:
Manufacturer: Sensirion Humidity Sensor
Model: SHT71
Accuracy: > 0.01%
Precision:
Calibration: Factory calibrated before purchase.
Comments:

Other Sensor

Description:
Manufacturer: Sunburst Sensors, LLC
Model: SAMI2 pH
Accuracy:
Precision:
Calibration: ~ Annually by Sunburst Sensors
Comments: pH data are collected and internally recorded during the CO₂ equilibration period. Data are salinity compensated with salinity collected by the Seabird SBE16, using the program Sunburst Sensors QC_PH_02. Spaulding, R., 2010. Salinity Measurement and SAMI-pH Accuracy. Tech Notes, 1.

**Additional
Information**

Suggested QC flag from Data Provider:
Additional Comments: o All measurements are at sea surface temperature and atmospheric pressure. o During the equilibration cycle, a closed loop of air equilibrates with seawater for 10 minutes. Once the equilibration period is complete, the pump stops and the system opens to the atmosphere allowing the

pressure to equilibrate with atmospheric pressure. Measurements are recorded for 30 seconds at 2 hertz and then averaged. o During the air cycle, fresh air is pumped through the detector for 1 minute. Once the pump stops, the system opens to the atmosphere allowing the pressure to equilibrate with atmospheric pressure. Measurements are recorded for 30 seconds at 2 hertz and then averaged. o The gas streams for both the air cycle and equilibrator cycle are partially dried before entering the detector. The values listed as wet xCO₂ generally have relative humidity levels ranging from 40 to 80 percent. The humidity levels increase over the course of a deployment. o Sampling occurs every 3 hours. The infrared detector is calibrated at the beginning of every sampling period. Averaged data and standard deviations for each measurement are transmitted back daily. o To calculate the dry measurements, the water mole fraction in the Licor detector must be known. A relative humidity sensor is located immediately downstream of the detector. o As part of the QC process, each data set is compared with the Marine Boundary Layer (MBL) data from GlobalView-CO₂. As part of the QC process, xCO₂ air measurements are compared to the following data sets when available: previous MAPCO₂ deployment if overlap on recovery/deployment, following MAPCO₂ deployment if overlap on recovery/deployment, and Marine Boundary Layer (MBL) xCO₂ air data from GlobalView-CO₂. The available comparison data sets are in good agreement with the MAPCO₂ air data and no adjustment was made. GLOBALVIEW-CO₂: Cooperative Atmospheric Data Integration Project - Carbon Dioxide. CD-ROM, NOAA ESRL, Boulder, Colorado [Also available on Internet via anonymous FTP to ftp.cmdl.noaa.gov, Path: ccg/co2/GLOBALVIEW], 2010 o During the QC process, an adjustment to the Licor pressure is also made based on each sensor' s bias to barometric pressure as measured in the lab. This system has Licor pressure bias of +0.200 applied. Post calculation correlation between Licor temperature and coefficient is: Licor coef = -0.001697 * Temp + 0.831 r² = 0.99 o No data = -9.999 or -999 o These data are made freely available to the public and the scientific community in the belief that their wide dissemination will lead to greater understanding and new scientific insights. The availability of these data does not constitute publication of the data. We rely on the ethics and integrity of the user to assure that PMEL receives fair credit for our work. Please send manuscripts using this data to PMEL for review before they are submitted for publication so we can insure that the quality and limitations of the data are accurately represented.

Citation for this Dataset:

Sutton, A., C. Sabine, S. Musielewicz, S. Maenner, R. Bott, and J. Osborne. 2016. High-resolution ocean and atmosphere pCO₂ time-series measurements from mooring LaPush_125W_48N.

Other References for this Dataset:

None